

大连虎滩新区污水处理厂2021年3月											
在线监测项目COD、氨氮、总氮、总磷、PH数据报表											
日期	处理水量 (m ³)	进水水质 (mg/L)					出水水质 (mg/L)				
		COD	NH3-N	TN	TP	pH	COD	NH3-N	TN	TP	pH
1	19,373	370.8	26.9			7.6	25.7	0.7	10.5	0.32	6.9
2	19,482	349.6	27			7.6	23.5	0.4	9.3	0.29	6.9
3	19,585	239.7	22.8			7.8	28.0	1.3	9.4	0.32	6.9
4	20,137	331.5	30.7			7.8	27.6	0.9	10.4	0.30	6.9
5	19,077	226.2	29.0			7.8	19.8	0.7	10.2	0.31	6.9
6	18,680	444.6	36.8			7.9	31.2	0.9	11.7	0.29	7.0
7	18,618	304.7	19.4			7.8	25.3	1.2	9.9	0.28	6.9
8	18,412	324.1	35.4			7.8	29.6	0.5	12.6	0.28	6.9
9	17,436	270.9	24.3			7.8	25.8	0.5	11.6	0.26	6.9
10	18,023	206.0	29.7			7.8	26.6	0.4	12.1	0.26	6.9
11	17,117	189.3	46.6			7.8	19.0	0.3	9.9	0.29	6.9
12	17,798	185.0	15.2			7.7	20.5	0.5	10.3	0.30	6.8
13	17,415	193.5	2.1			7.7	21.9	2.1	10.0	0.28	6.8
14	17,880	180.5	1.4			7.7	20.2	0.6	10.5	0.31	6.8
15	16,564	232.0	38.1			7.8	23.0	1.1	10.8	0.30	6.8
16	17,118	289.2	31.3			8	21.9	0.5	8.2	0.28	6.9
17	17,202	305.1	30.3			7.9	24.1	0.3	6.4	0.25	6.9
18	16,603	210.3	32.9			7.8	23.0	1.0	10.2	0.25	6.9
19	17,531	151.9	30.9			7.7	25.4	0.4	7.4	0.26	6.9
20	17,816	295.0	19.6			7.7	24.7	0.3	12.5	0.26	6.9
21	17,669	316.1	19.6			7.7	23.5	0.3	10.3	0.23	6.9
22	16,959	243.1	18.2			7.7	25.6	0.3	12.8	0.24	6.9
23	17,152	265.1	19.4			7.7	23.3	0.2	11.7	0.22	6.9
24	16,476	287.6	18.0			7.7	35.7	0.2	10.8	0.24	6.9
25	16,838	340.7	20.7			7.9	23.9	0.2	11.6	0.25	6.9
26	16,631	330.8	21.3			7.9	27.2	0.2	9.9	0.24	7.0
27	17,048	180.5	20.3			7.8	27.5	0.6	12.2	0.26	7.0
28	16,374	156.9	18.8			7.7	26.9	0.9	13.5	0.25	6.9
29	17,011	186.5	15.6			7.7	30.0	0.3	11.4	0.26	6.9
30	15,828	207.0	17.2			7.7	24.9	0.2	12.2	0.25	6.9
31	15,995	170.6	16.7			7.5	21.3	0.3	11.0	0.22	6.9
均值	17,608	257.6	23.7			7.8	25.1	0.6	11.0	0.27	6.9

填表人：段晓辰

日期：2021年2月2日

(公章)